# 2013 Drinking Water Report, Camden

#### Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

#### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

#### Where does my water come from?

Your water source is from two wells pumping from the Meridian Upper Wilcox Aquifer.

#### Source water assessment and its availability

To obtain additional information about your drinking water, you may contact our certified water works operator, Mr. Claudie Steen at 601-859-2474, or you may prefer to log on to the Internet and obtain specific information about your system and it's compliance history at the following address http://www.msdh.state.us/watersupply/index.htm

#### Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater

runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

#### How can I get involved?

The Canton Municipal Utilities Board meets on the first and third Tuesday of each month at 2:00PM at 127 West Peace Street. We encourage all customers who may have any questions or concerns to meet with us.

#### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Canton Municipal Utilities-Cambden is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

# **Water Quality Data Table**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

MCLG	MCL,			

	or .	TT, or	Your	Ra	nge	Sample		ļ	
<u>Contaminants</u>	MRDLG	MRDL	<u>Water</u>	Low	Higl	<u>Date</u>	<u>Viol</u>	<u>lation</u>	<u>Typical Source</u>
Disinfectants & Disin	nfectant By	-Produ	ets						
(There is convincing e	vidence tha	t additio	n of a disi	nfectai	nt is n	ecessary fo	r cont	trol of r	nicrobial contaminants)
Haloacetic Acids (HAA5) (ppb)	NA	60	30	NA		2013	1	No	By-product of drinking water chlorination
Chlorine (as Cl2) (ppm)	4	4	1.9	1.1	2.6	2013	1	No	Water additive used to control microbes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	50.5	NA		2013	ſ	No	By-product of drinking water disinfection
Inorganic Contamin	ants								
Barium (ppm)	2	2	0.00786	0.006 55	0.00 86	7 2012	ì	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.304	0.121	0.30	4 2012	1	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Chromium (ppb)	100	100	9.57	5.27	9.57	2012	1	No	Discharge from steel and pulp mills; Erosion of natural deposits
			Your	Sam	ple	# Sample	es	Exceed	ls
<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Water</u>	<u>Dat</u>	<u>e</u> ]	Exceeding	<u>AL</u>	<u>AL</u>	Typical Source
Inorganic Contamin	ants								
Copper - action level at consumer taps (ppm)	1.3	1.3	0.2	201		0		No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	1	201	***************************************	0		No	Corrosion of household plumbing systems; Erosion of natural deposits

Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (μg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions						
Term	Definition					
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.					

MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

Contact Name: Mark snow

Address:

255 N. Hargon Strett Canton, MS 39046 Phone: 601-506-3345 Fax: 601-855-5445

# 2013 Drinking Water Report, City of Canton

#### Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

#### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

#### Where does my water come from?

Your water comes from 4 wells pumping from the Sparta Sand Aquifer.

#### Source water assessment and its availability

To obtain additional information about your drinking water you may contact our certified water, Mr. Claudie Steen, at 601-859-2474 or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address http://www.msdh.state.us/watersupply/index.htm

#### Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment

plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

#### How can I get involved?

The Canton Municipal Utilities Board meets the first and third Tuesday of each month at 2:00 PM at 127 West Peace Street. We encourage all customers who have any concerns or questions to meet with us.

#### Other Information

To comply with the "Regulation Governing Fluoridation of Community Water Supplies" CITY OF CANTON is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 96%.

#### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Canton Municipal Utilities, City of Canton is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

# Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed

below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

	MCLG	MCL,	37	D.		Commis			
Contaminants	or MRDLG	TT, or	Your <u>Water</u>	Low	nge Hiol	Sample Date	l	ation	Typical Source
Disinfectants & Disin				2011	22.5.	Ditte			
				nfectai	nt is n	ecessary fo	or cont	rol of 1	nicrobial contaminants)
Haloacetic Acids (HAA5) (ppb)	NA	60	9	2	9	2013		Vo	By-product of drinking water chlorination
Chlorine (as Cl2) (ppm)	4	4	2.4	1	3.2	2013	1	Vo	Water additive used to control microbes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	8.83	5.4	8.83	2013	ì	Мо	By-product of drinking water disinfection
Inorganic Contamin	ants								
Barium (ppm)	2	2	0.0235	NA		2013	1	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.932	0.7	1.5	2012		No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Chromium (ppb)	100	100	0.0011	NA		2013	1	No	Discharge from steel and pulp mills; Erosion of natural deposits
			Your	Sam	* }	# Sampl	1	Excee	
<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	Water	<u>Da</u>	te j	Exceeding	AL	<u>AL</u>	<u>Typical Source</u>
Inorganic Contamin	ants	T							
Copper - action level at consumer taps (ppm)	1.3	1.3	0	20	13	0		No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	3	20	13	0		No	Corrosion of household plumbing systems; Erosion of natural deposits

nit Descriptions					
Term	Definition				
ppm	ppm: parts per million, or milligrams per liter (mg/L)				
ppb	ppb: parts per billion, or micrograms per liter (μg/L)				

NA NA	NA; not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definition	S
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

Contact Name: Mark snow

Address:

Address: 225 North Hargon Street Canton, MS 39046 Phone: 601-506-3345 Fax: 601-855-5445

# 2013 Drinking Water Report, Lake Caroline

#### Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

#### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

#### Where does my water come from?

Your water comes from two wells pumping from the Sparta Sand Aquifer.

#### Source water assessment and its availability

To obtain additional information about your drinking water, you may contact our certified water works operator, Mr. Claudie Steen, at 601-859 2474, or you may prefer to log on to the Internet and obtain specific information about your system and it's compliance history at the following address http://www.msdh.state.us/watersupply/index.htm.

#### Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment

plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

#### How can I get involved?

The Canton Municipal Utilities Board meets on the first and third Tuesday of each month at 2:00 PM at 127 West Peace Street. We encourage all customers who have any concerns or questions to meet with us.

#### **Description of Water Treatment Process**

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

#### **Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lake Caroline is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

# **Water Quality Data Table**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless

otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

	MCLG	MCL,	1						
		} `	1	<sub>Da</sub>	200	Cample			
	Or	TT, or	1		nge	Sample			m + 16
<u>Contaminants</u>	MRDLG		<u> </u>	Low	Higi	<u>Date</u>	<u>V10</u>	olation	<u>Typical Source</u>
Disinfectants & Disir									
(There is convincing e	vidence tha	t additio	n of a disi	nfecta	nt is n	ecessary fo	r cor	itrol of i	nicrobial contaminants)
Haloacetic Acids (HAA5) (ppb)	NA	60	4	NA		2013		No	By-product of drinking water chlorination
Chlorine (as Cl2) (ppm)	4	4	2.4	1.2	3.1	2013		No	Water additive used to control microbes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	8,67	NA		2013		No	By-product of drinking water disinfection
Inorganic Contamin	ants				•				
Barium (ppm)	2	2	0.0127	NA		2013		No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.105	NA		2013		No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrite [measured as Nitrogen] (ppm)	1	1	0.05	ND	0.05	2013		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Chromium (ppb)	100	100	1.7	NΑ		2013		No	Discharge from steel and pulp mills; Erosion of natural deposits
			Your	Sam	ple	# Sample	es	Exceed	ls
<u>Contaminants</u>	MCLG	<u>AL</u>	Water	<u>Da</u>	<u>e</u> []	Exceeding	AL	AL	Typical Source
Inorganic Contamin	ants	·	*		······································				
Copper - action level at consumer taps (ppm)	1.3	1.3	0.5	201	12	0		No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	4	201	12	0		No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions					
Term	Definition				
ppm	ppm: parts per million, or milligrams per liter (mg/L)				
ppb	ppb: parts per billion, or micrograms per liter (μg/L)				

NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definition	ns
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

Contact Name: Mark snow

Address:

225 North Hargon Street Canton, MS 39046 Phone: 601-506-3345 Fax: 601-855-5445

# 2013 Drinking Water Report, Levi

#### Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. Last year, we conducted tests for over 80 contaminants. We only detected 11 of those contaminants, and found only 1 at a level higher than the EPA allows. As we informed you at the time, our water temporarily exceeded drinking water standards. (For more information see the section labeled Violations at the end of the report.)

#### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

#### Where does my water come from?

Your water source is the Sparta Sand Aquifer.

## Source water assessment and its availability

To obtain additional information about your drinking water you may contact our certified water works operator, Mr. Claudie Steen, at 601-859-2474, or you may prefer to log on to the Internet and obtain specific information about your system and it's compliance history at the following address: http://www.msdh.state.us/watersupply/index.htm

## Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material,

and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

#### How can I get involved?

The Canton Municipal Utilities' Board meets on the first and third Tuesday of each month at 2:00PM at 127 East Peace Street. We encourage all customers who have any concerns or questions to meet with us.

#### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Canton Municipal Utilities-Levi is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

# Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will

find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

	MCLG or	MCL, TT, or	Your	Ra	nge	Sample				
<u>Contaminants</u>	MRDLG	MRDL	<u>Water</u>	Low	High	<u>Date</u>	Viol	lation		Typical Source
Disinfectants & Disinfectant By-Products										
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)										
Haloacetic Acids (HAA5) (ppb)	NA	60	69	47	69	2013	7	7es	By-product of drinking wat	
Chlorine (as Cl2) (ppm)	4	4	1.1	0.3	1.6	2013	]	No		ater additive used to control crobes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	60	36	60	2013	]			r-product of drinking water sinfection
Inorganic Contamin	ants				,					
Barium (ppm)	2	2	0.00782	NA		2012	]	No	Di ref	scharge of drilling wastes; scharge from metal fineries; Erosion of natural posits
Fluoride (ppm)	4	4	0.144	NA		2012		No	W. pro Di	osion of natural deposits; ater additive which omotes strong teeth; scharge from fertilizer and aminum factories
Chromium (ppb)	100	100	5.7	NA		2012		No m		scharge from steel and pulp ills; Erosion of natural posits
Cyanide [as Free Cn] (ppb)	200	200	15	NA		2012		No fe		scharge from plastic and rtilizer factories; Discharge om steel/metal factories
Volatile Organic Con	ntaminant	S								
Xylenes (ppm)	10	10	0.00413	NA		2012	]	No fa		scharge from petroleum stories; Discharge from emical factories
Ethylbenzene (ppb)	700	700	0.517	NA		2012	ו	Vo		scharge from petroleum ineries
<u>Contaminants</u>	MCLG	<u>AL</u>	Your <u>Water</u>	Sam <u>Da</u>	- /	# Sampl Exceeding	l	L		Typical Source
Inorganic Contamin	ants									
Copper - action level at consumer taps (ppm)	1.3	1.3	0.4	20	12	0		No		Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	2	20	12	0		No		Corrosion of household plumbing systems; Erosion of natural deposits

Violations and Exceedances
Haloacetic Acids (HAA5)

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer. Our system exceeded the HAA5MCL at one location during the first quarter of 2013. We continue to work closely with the Mississippi State Department of Health to resolve this situation through modified operational practices. The system is currently in compliance.

Descriptions						
Term	Definition					
ppm	ppm: parts per million, or milligrams per liter (mg/L)					
ppb	ppb: parts per billion, or micrograms per liter (μg/L)					
NA	NA: not applicable					
ND	ND: Not detected					
NR	NR: Monitoring not required, but recommended.					

ortant Drinking Water Definition	1S
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

#### For more information please contact:

Contact Name: Mark snow

Address:

225 North Hargon Street Canton, MS 39046 Phone: 601-506-3345 Fax: 601-855-5445

# 2013 Drinking Water Report, Way Road

#### Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

## Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## Where does my water come from?

Your water is from one well pumping from the Meridian Upper Wilcox Aquifer.

## Source water assessment and its availability

To obtain information about your drinking water, you may contact our certified water works operator, Mr. Cludie Steen, at 601-859-2474, or you may prefer to log on to the Internet and obtain specific information about your system and it's compliance history at the following address http://www.msdh.state.us/watersupply/index.htm

# Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater

runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

#### How can I get involved?

The Canton Municipal Utilities Board meets on the first and third Tuesday of each month at 2:00PM at 127 West Peace Street. We encourage all customers who have any questions or concerns to meet with us.

### **Description of Water Treatment Process**

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

#### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Canton Municipal Utilities, Way Road is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

# **Water Quality Data Table**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these

contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

	MCLG	MCL,				T					
	or	TT, or	Your	Ra	nge	1	Sample		:		
<u>Contaminants</u>	MRDLG	MRDL	Water	Low	<u>Higl</u>	<u>1</u>	<u>Date</u>	<u>Vio</u>	<u>lation</u>		Typical Source
Disinfectants & Disinfectant By-Products											
(There is convincing e	vidence tha	t additio	n of a disi	nfectar	ıt is n	ec	essary fo	r con	trol of r	nicr	obial contaminants)
Haloacetic Acids (HAA5) (ppb)	NA	60	26	22	26		2013		No	By-product of drinking water chlorination	
Chlorine (as Cl2) (ppm)	4	4	1.1	0.2	2		2013	-	No I		nter additive used to control crobes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	47.3	46	47.3	3	2013		No	By-product of drinking water disinfection	
Inorganic Contamin	ants										
Barium (ppm)	2	2	0.00736	0.003 48	0.00 36	- 1	2012		No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
Fluoride (ppm)	4	4	0.296	0.28	0.29	)6	2012		Water additive which No promotes strong teeth;		omotes strong teeth; scharge from fertilizer and
Chromium (ppb)	100	100	13.03	1.92	13.0	)3	2012	No		mi	scharge from steel and pulp lls; Erosion of natural posits
		Ī	Your	Sam	ple		# Sampl	es	Excee	ds	
<u>Contaminants</u>	MCLG	AL	Water	Dat	te (	<u>E</u>	xceeding	AL	<u>AL</u>		Typical Source
Inorganic Contamin	ants										
Copper - action level at consumer taps (ppm)		1.3	0.3	20	11		0	No			Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	4	20	11		0		No		Corrosion of household plumbing systems; Erosion of natural deposits

Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ррь	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
ТТ	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

Contact Name: Mark snow

Address:

225 North Hargon Street Canton, MS 39046 Phone: 601-506-3345 Fax: 601-855-5445